

SitelogIQ HVAC Audit Form

Site: Allen Hancock Community College

	School Site	Classroom # or Area Served	Unit Type	Manufacturer	Configuration	Model #	Serial #	Nominal Tons	Year Installed	Electrical Service	Heating Load, MBH In/Out	Electrical Heater, KW	Supply Air Blower, HP or AMP.	Economizer Functioning If applic.	Priority
1	Bldg. B 100/200 (VC)	B	PKG VAV	McQuay	SD	RP5036CLY	FBOU110701360	36	2011	460/3	N/A	N/A	20 HP	Yes	2
2	Bldg. B 100/200 (VC)	B Elevator Rm	HP	Carrier	Mini Split	38HDR018---3	1911X92310	1.5	2011	230/1	N/A	N/A	N/A	N/A	2
3	Bldg. B 100/200 (VC)	B IT Rm	HP	Mitsubishi	Mini Split	MUZ-HM18NA	97C01826	1.5	2009	230/1	N/A	N/A	N/A	N/A	2
4	Bldg. B 100/200 (JR)	B100	PKG G/E	York	SD	ZH150S15N4LZZ50001A	N1D2755055	12.5	2012	460/3	180/108	N/A	5 HP	Yes	3
5	Bldg. B 100/200 (JR)	Server	HP	Mitsubishi	Mini Split	MU-A09WA	1001187 T	0.75	2011	115/1	N/A	N/A	N/A	N/A	2
6	Bldg. B 100/200 (JR)	Server	HP	Mitsubishi	Mini Split	MUYGE24NA	1005314 T	2	2011	230/1	N/A	N/A	N/A	N/A	2
7	Bldg. A 100/200 (VC)	A100/200	HP	Mitsubishi	Mini Split	MUY-GE24NA	1003425T	2	2011	230/1	N/A	N/A	N/A	N/A	2
8	Bldg. A 100/200 (VC)	A100/200	HP	Carrier	Mini Split	38HDR024---3	2811X92097	2	2011	230/1	N/A	N/A	N/A	N/A	2
9	Bldg. A 100/200 (VC)	A100/200	HP	Mitsubishi	Mini Split	MUY-GL24NA	5001544T	2	2015	230/1	N/A	N/A	N/A	N/A	3
10	Bldg. A 100/200 (VC)	A 100/200	PKG VAV	McQuay	SD	RDT090DLY	FBOU110701169 00	90	2011	460/3	N/A	N/A	50	Yes	2
11															
12	Bldg. A 300/400 (VC)	A 300/400	PKG VAV	McQuay	SD	RDT045CSY	FBOU110701171 02	45	2011	460/3	N/A	N/A	25 HP	Yes	2
13	Bldg. G (VC)	G (AC-9)	PKG G/E	ICP	DF	RGS090LDCA0AATA	P193036428	7.5	2019	460/3	125/103	N/A	3.8 A	Yes	4
14	Bldg. G (VC)	G (AC-8)	PKG G/E	ICP	SD	RGS150LDCA0AATA	P201341099	12.5	2020	460/3	180/140	N/A	4.9 A	Yes	4
15	Bldg. G (VC)	G	PKG G/E	Carrier	SD	48HJD009---631--	1101G34330	8.5	2001	460/3	125/102.5	N/A	3.4 A	Yes	1
16	Bldg. G (VC)	G	PKG G/E	Carrier	DF	48HJD007---641--	3301G21205	6	2001	460/3	72/59	N/A	2.6 A	Yes	1
17	Bldg. G (VC)	G	PKG G/E	Carrier	DF	48HJD007---641--	3301G21208	6	2001	460/3	72/59	N/A	2.6 A	Yes	1

SitelogIQ HVAC Audit Form

Site: Allen Hancock Community College

Date: 7/1/2021

Auditor: VC, JR

	School Site	Classroom # or Area Served	Unit Type	Manufacturer	Configuration	Model #	Serial #	Nominal Tons	Year Installed	Electrical Service	Heating Load, MBH In/Out	Electrical Heater, KW	Supply Air Blower, HP or AMP.	Economizer Functioning If applic.	Priority
1	Bldg. G (VC)	G	PKG G/E	Carrier	SD	48HJD012---671--	3701G32231	10	2001	460/3	180/147.6	N/A	4.8 A	Yes	1
2	Bldg. G (VC)	G (AC-2)	PKG G/E	Carrier	DF	48TCDD09A2A6A0A0A0	1811G40584	8.5	2011	460/3	125/103	N/A	2.6 A	No Econo	2
3	Bldg. G (VC)	G (AC-3)	PKG G/E	Carrier	SD	48HJD007---641--	3301G21207	6	2001	460/3	72/59	N/A	2.6 A	Yes	1
4	Bldg. G (VC)	G (AC-5)	PKG G/E	Carrier	SD	48HJD009---631--	1101G34328	8.5	2001	460/3	125/102.5	N/A	3.4 A	Yes	1
5	Bldg. G (VC)	G (AC-5)	PKG G/E	ICP	SD	RG5120LDCA0AATA---	P191640415	10	2019	460/3	180/148	N/A	4.9 A	Yes	4
6	Bldg. G (VC)	G (AC-4)	PKG G/E	Carrier	DF	48HJL005---641--	3301G23436	4	2001	460/3	60/50	N/A	2.2 A	No Econo	1
7	Bldg. H (VC)	H	PKG G/E	Lennox	DF	TGA180H2BM1G	5607A03248	15	2007	460/3	480/384	N/A	5 HP	Yes	2
8	Bldg. H (VC)	H	PKG G/E	Trane	SD	4YCC302481064AA	10255WH49H	2.5	2010	230/1	64/51.5	N/A	1/4 HP	No Econo	2
9	Bldg. H (VC)	H	PKG G/E	Goodman	SD	PG120250-3AB	9504802541	10	1995	230/3	230/184	N/A	3 HP	No Econo	1
10	Bldg. I 200 (VC)	I 200 (AC-6J)	PKG G/E	Carrier	DF	48TCLA04A1A3A2A0D0	2612C86424	3	2012	230/1	60/47	N/A	4.9 A	Yes	3
11	Bldg. I 200 (VC)	I 200 (AC-5J)	PKG G/E	Carrier	DF	48TCLA06A1A5A2A0D0	2712C86459	5	2012	230/3	60/50	N/A	4.9 A	Yes	3
12	Bldg. I 200 (VC)	I 200 (AC-4I)	PKG G/E	Carrier	DF	48TCSA08A1A5A2A0D0	2912G30376	7.5	2012	230/3	125/103	N/A	5.2 A	Yes	3
13	Bldg. I 200 (VC)	I 200 (AC-3I)	PKG G/E	Carrier	DF	48HJD008---541--	5005G40602	7.5	2005	230/3	125/102.5	N/A	7.5 A	Yes	1
14	Bldg. I 200 (VC)	I 200 (AC-2I)	PKG G/E	Carrier	DF	48TCSA08A1A5A2A0D0	2912G30377	7.5	2012	230/3	125/103	N/A	5.2 A	Yes	3
15	Bldg. I 200 (VC)	I 200 (AC-1I)	PKG G/E	Carrier	DF	48TCLA04A1A3A2A0D0	2612C86426	3	2012	230/1	60/50	N/A	4.9 A	Yes	3
16	Bldg. I 100 (VC)	I 100 (AC-1)	PKG G/E	AAON	SD	RQ-003-8-H-EA89-319	201207-AYGC03699	3	2012	208/3	60/48.6	N/A	2 HP	No Econo	3
17	Bldg. I 100 (VC)	I 100 (AC-2)	PKG G/E	AAON	SD	RQ-003-8-V-EA89-319	201207-AYGC03700	3	2012	208/3	60/48.6	N/A	1 HP	No Econo	3

Sitelog HVAC Audit Form

Page: 3 of 10
 Date: 7/1/2021
 Auditor: VC, JR

Site: Allen Hancock Community College

	School Site	Classroom # or Area Served	Unit Type	Manufacturer	Configuration	Model #	Serial #	Nominal Tons	Year Installed	Electrical Service	Heating Load, MBH In/Out	Electrical Heater, KW	Supply Air Blower, HP or AMP.	Filter Rating (MERV)	Fresh Air Opening Size**	Economizer Functioning If applic.	Priority
1	Bldg. I 100 (VC)	I 100 (AC-3)	PKG G/E	AAON	SD	RQ-003-8-H-EA89-319	201207-AYGC03701	3	2012	208/3	60/48.6	N/A	2 HP			No Econo	3
2	Bldg. I 100 (VC)	I 100 (AC-4)	PKG G/E	AAON	DF	RQ-004-8-V-EA89-319	201207-AYGD03702	4	2012	208/3	60/48.6	N/A	2 HP			No Econo	3
3	Bldg. I 100 (VC)	I 100 (AC-5)	PKG G/E	AAON	DF	RQ-004-8-H-EA89-319	201207-AYGD03703	4	2012	208/3	60/48.6	N/A	2 HP			No Econo	3
4	Bldg. I 100 (JR)	Data	HP	Mitsubishi	Mini Split	PUY-A24NHA4	111U05889B	2	2011	208-1	N/A	N/A	N/A	N/A	N/A	N/A	2
5	Bldg. I 100 (JR)	Electric Rm	HP	Mitsubishi	Mini Split	PUY-A12NHA4	25U06186C	1	2011	208-1	N/A	N/A	N/A	N/A	N/A	N/A	2
6	Bldg. I 100 (JR)	Electric Rm	HP	Mitsubishi	Mini Split	PUY-A18NHA4	25406320C	1.5	2011	208-1	N/A	N/A	N/A	N/A	N/A	N/A	2
7	Bldg. I 100 (JR)	I 111	PKG G/E	AAON	SD	RQ-004-8-H-EA89-319	201207-AYGD03704	4	2012	208-3	60/48	N/A	2 HP	13	-	YES	3
8	Bldg. M 400 (VC)	M 430	Hydronic Heat	Herman Nelson	UF	No nameplate data										No Econo	Phase 2
9	Bldg. M 400 (VC)	M 431	Hydronic Heat	Herman Nelson	UF	No nameplate data										No Econo	Phase 2
10	Bldg. M 400 (VC)	M 433	Hydronic Heat	Herman Nelson	UF	No nameplate data										No Econo	Phase 2
11	Bldg. M 400 (VC)	M 433	Hydronic Heat	Herman Nelson	UF	No nameplate data										No Econo	Phase 2
12	Bldg. M 400 (VC)	M 434	Hydronic Heat	Herman Nelson	UF	No nameplate data										No Econo	Phase 2
13	Bldg. M 400 (VC)	M 434	Hydronic Heat	Herman Nelson	UF	No nameplate data										No Econo	Phase 2
14	Bldg. M 400 (VC)	M 434B	Hydronic Heat	Herman Nelson	SD	No nameplate data										No Econo	Phase 2
15	Bldg. M 400 (VC)	M 438	Hydronic Heat	Herman Nelson	UF	No nameplate data										No Econo	Phase 2
16	Bldg. M 400 (VC)	M 439	Hydronic Heat	Herman Nelson	UF	No nameplate data										No Econo	Phase 2
17	Bldg. M 400 (JR)	M400-433A	PKG G/E	Trane	SD	4YCC3048A1075AB	10094YM09H	4	2010	208-1	75/60	N/A	3/4 HP			None	2

SitelogIQ HVAC Audit Form

Site: Allen Hancock Community College

Date: 7/1/2021

Auditor: VC, JR

	School Site	Classroom # or Area Served	Unit Type	Manufacturer	Configuration	Model #	Serial #	Nominal Tons	Year Installed	Electrical Service	Heating Load, MBH In/Out	Electrical Heater, KW	Supply Air Blower, HP or AMP.	Economizer If applic.	Priority
1	Bldg. M 300 (VC)	M311-312 (F-1)	Split CU	IDU:Reznor (2)ODU:Carrier	UF	IDU: ACUB120 (2)ODU: 38HDR060---S	IDU: BHL-05892 (2)ODU:Unreadable	(2)5T ODU's/ 10T IDU	2008	208/1	N/A	N/A	N/A	No Econo	2
2	Bldg. M 300 (VC)	M300/HALL (F-2)	Split CU	IDU:Reznor ODU:Carrier	UF	IDU: ACUA060 ODU: 38HDR060---S	IDU: BHL-05891 ODU:Unreadable	5T ODU/ 5T IDU	2008	208/1	N/A	N/A	N/A	No Econo	2
3	Bldg. M 300 (VC)	M Offices	PKG G/E	ICP	DF	PGB060E1LC	L9830 64316	5	1998	460/3	115/91	N/A	1 HP	Yes	1
4	Bldg. M 200 (VC)	M	Hydronic Heat (AC-4)	AAON	DF	RM-013-3-0-AB22-EHL	200607-AMWK01672	13	2006	460/3	N/A	N/A	7.5 HP	Yes	Phase 2
5	Bldg. M 200 (VC)	M	Hydronic Heat (AC-5)	AAON	DF	RM-013-3-0-AB22-EHL	200607-AMWK01671	13	2006	460/3	N/A	N/A	7.5 HP	Yes	Phase 2
6	Bldg. M 200 (VC)	M	Hydronic Heat (AC-6)	AAON	DF	RM-013-3-0-AB22-EHL	200607-AMWK01673	13	2006	460/3	N/A	N/A	7.5 HP	Yes	Phase 2
7	Bldg. M 200 (VC)	1st Floor	PKG VAV (AH-1)	McQuay	DF	RPS025CLW	FBQU060700820 00	25	2006	460/3	See notes	N/A	15 HP	Yes	1
8	Bldg. M 200 (VC)	2nd Floor	PKG VAV (AH-3)	McQuay	DF	RPS025CLW	FBQU060700821 00	25	2006	460/3	See notes	N/A	15 HP	Yes	1
9	Bldg. M 200 (VC)	M	HP	Carrier	Mini Split	38BNC018301	Serial # portion of tag ripped off	1.5	unknown	230/1	N/A	N/A	N/A	No Econo	No replacement
10	Bldg. M 100 (JR)	M 100	PKG VAV	MCQUAY	DF	RPS036CLW	FBQU060700834	36	2011	460-3	N/A	N/A	15 HP	Yes	2
11	Bldg. M 100 (JR)	Elevator Mech	HP	MITSUBISHI	Mini Split	24H46ZOMI	340694342018813013007	2	2011	208-1	N/A	N/A	N/A	N/A	2
12	Bldg. M 100 (JR)	Elevator Mech	HP	MITSUBISHI	Mini Split	24H45ZOMI		2	2011	208-1	N/A	N/A	N/A	N/A	2
13	Bldg. L (VC)	IT	HP	Fujitsu	Mini Split	AOU36RLXB	FTN019681	3	2017	230/1	34	N/A	IDU	N/A	4
14	Bldg. L (VC)	IT	HP	Fujitsu	Mini Split	AOU36RLXB	FTN019683	3	2017	230/1	34	N/A	IDU	N/A	4
15	Bldg. L (VC)	IT	HP	Fujitsu	Mini Split	AOU36RLXB	FTN019682	3	2017	230/1	34	N/A	IDU	N/A	4
16	Bldg. L (JR)	Half of Bldg.	PKG G/E	Octagon	DF	OAS-451-18C-700G-MZ	13190298016	45	1998	460-3	700/	N/A	20 HP	Yes	1
17	Bldg. L (JR)	Half of Bldg.	PKG G/E	Octagon	DF	OAS-45T-18C-700G-MZ	13190298017	45	1998	460-3	700/	N/A	20 HP	Yes	1

SitelogIQ HVAC Audit Form

Site: Allen Hancock Community College

Date: 7/1/2021

Auditor: VC, JR

	School Site	Classroom # or Area Served	Unit Type	Manufacturer	Configuration	Model #	Serial #	Nominal Tons	Year Installed	Electrical Service	Heating Load, MBH In/Out	Electrical Heater, KW	Supply Air Blower, HP or AMP.	Economizer Functioning If applic.	Priority
1	Bldg. L (JR)	L332 (STACKS)	PKG G/E	Octagon	DF	OAS-28T-10C-300G-MZ	13190298018	28	1998	460-3	300	N/A	10 HP	YES	1
2	Bldg. L (JR)	ARC (L)	PKG G/E	Carrier	SD	48AYM030-Q-20052	4005U06301	30	2005	460-3	350/283	N/A	20 HP	YES	1
3	Bldg. L (JR)	ARC (L)	PKG G/E	Carrier	SD	48AYM030-Q-20052	4005U06302	30	2005	460-3	350/283	N/A	20 HP	YES	1
4	Bldg. K (VC)	K13,13F,13H,13J,11B,14,14A	PKG HP	ICP	SD	PHE090H000AA----	G080821471	7.5	2008	230/3	N/A	24.3 KW	7.5 A	No Econo	1
5	Bldg. K (VC)	K 10	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2
6	Bldg. K (VC)	K 11B	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2
7	Bldg. K (VC)	K 12	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2
8	Bldg. K (VC)	K11	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2
9	Bldg. K (VC)	CRC	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2
10	Bldg. K (VC)	K200-205, K211-213, K20-22	PKG VAV	McQuay	SD	RDS8020LY	FBOU01060032800	30	2001	460/3	N/A	N/A	10 HP	Yes	1
11	Bldg. K (JR)	2nd Floor	Air cooled water chiller	McQuay	N/A	AC2050A527-ER10	STN4010600098	50	2001	460-3					1
12	Bldg. D (VC)	Dance Studio (AH-3)	Hydronic	Alliance	SD	3NN-7.1-15-FF-CW-PF-GD	1854AH3		2013	230/3			5 HP	No Econo	3
13	Bldg. D (VC)	Audience (AH-1)	Hydronic	Alliance	SD	3VN-21.3-MB-FF-CW-PF-GD	1854AH1		2013	230/3			10 HP	Yes	3
14	Bldg. D (VC)	Backstage (AH-2)	Hydronic	Alliance	SD	3VN-15-MB-FF-CW-PF-GD	1854AH2		2013	230/3			5 HP	Yes	3
15	Bldg. D (VC)	D103	PKG G/E	ICP	DF	RG5048HMAA0AAAAA---	C152064674	4	2015	230/3	90/74	N/A	5.2 A	Yes	3
16	Bldg. D (VC)	D104, 105 (AC-4)	PKG G/E	Carrier	DF	48SB-024060301--	1292C45942	2	1992	230/1	60/48.6	N/A	?	No Econo	1
17	Bldg. D (VC)	D106, 174 (AC-3)	PKG G/E	Carrier	DF	48DJ0005530	3492G54223	4	1992	230/3	74/59.9	N/A	3.1 A	No Econo	1

SiteLogIQ HVAC Audit Form

Site: Allen Hancock Community College

Date: 7/1/2021

Auditor: VC, JR

	School Site	Classroom # or Area Served	Unit Type	Manufacturer	Configuration	Model #	Serial #	Nominal Tons	Year Installed	Electrical Service	Heating Load, MBH In/Out	Electrical Heater, KW	Supply Air Blower, HP or AMP.	Economizer Functioning If applic.	Priority
1	Bldg. D (JR)	D110-117/ D154-155	PKG G/E	Carrier	DF	48HCDD09A2A5A0A0A0	0313G30115	8.5	2013	230/3	125/103	N/A	6.9 FLA	Yes	3
2	Bldg. D (JR)	D 176	HP	Mitsubishi	Mini Split	PUMY-P36NHMU-BS	2XU00042A	3	2012	230/1	N/A	N/A	N/A	N/A	3
3	Bldg. D (JR)	D119-156	PKG G/E	Carrier	DF	48VLNA2404030--	4812C10578	2	2012	230/1	40/32	N/A	1/2 HP	No Econo	3
4	Bldg. D (JR)	D157,172 Area	PKG G/E	Carrier	SD	48HCDD12A2A5A0A0A0	0613G50132	10	2013	230/3	180/148	N/A	10.6 FLA	Yes	3
5	Bldg. D (JR)	Hallway	PKG G/E	Carrier	SD	48HCDD12A2A5A0A0A0	0513G50135	10	2013	230/3	180/148	N/A	10.6 FLA	Yes	3
6	Bldg. D (JR)	Hallway	HP	Mitsubishi	Mini Split	PUMY-P48NHMU-BS	2YU00021A	4	2012	230/1	N/A	N/A	N/A	N/A	3
7	Bldg. D (JR)	Severson Theatre	PKG G/E	Carrier	SD	48TCFD24A7K5A0B0A0	2210U12291	20	2010	230/3	40/32	N/A	19.4 FLA	Yes	2
8	Bldg. D (JR)	D100	PKG G/E	Carrier	DF	48SB-024060301--	1292C45947	2	1992	230/1	60/	N/A		No Econo	1
9	Bldg. C (VC)	C (AC-1)	PKG HP	York	SD	B1CH048A25B	Nameplate unreadable	4	90s	Nameplate unreadable	Nameplate unreadable	Nameplate unreadable	Nameplate unreadable	No Econo	1
10	Bldg. C	C (AC-2)	PKG HP	York	SD	P1CH060A25A	Nameplate unreadable	5	90s	Nameplate unreadable	Nameplate unreadable	Nameplate unreadable	Nameplate unreadable	No Econo	1
11	Bldg. C	C	PKG HP	York	SD	B3CH060A25C	N0L4051636	5	2004	230/3	N/A	N/A	1 HP	No Econo	1
12	Bldg. C	C	PKG G/E	Carrier	SD	48HJD014--561--	3501G33260	12.5	2001	230/3	224/147.6	N/A	15 A	Yes	1
13	Bldg. C (JR)	C40	Split HP	Trane	DF	IDU:TWE090E300AA ODU:TWA090E30RAA	IDU:181137FGBA ODU:18094TS5YA	7.5	2018	230/3	90/	N/A	1.5 HP	N/A	4
14	Bldg. C (JR)	C40A	HP	Mitsubishi	Mini Split	Could not access this unit	Could not access this unit	1.5?	Could not access this unit.						
15	Bldg. C (JR)	C30-33	PKG G/E	Carrier	SD	48HJD014--561--	3501G33261	12.5	2001	230/3	224/147	N/A	15 FLA	Yes	1
16	Bldg. S (VC)	S (AC 1-5)	PKG G/E	Carrier	DF	48HJH004-M-541HQ	2306G40400	3	2006	230/3	72/59	N/A	5.8 A	Yes	1
17	Bldg. S (VC)	S (AC 1-2)	PKG G/E	Carrier	DF	48HJH006-M-541HQ	2106G20324	5	2006	230/3	115/93.2	N/A	7.5 A	Yes	1

SitelogIQ HVAC Audit Form

Site: Allen Hancock Community College

Date: 7/1/2021

Auditor: VC, JR

	School Site	Classroom # or Area Served	Unit Type	Manufacturer	Configuration	Model #	Serial #	Nominal Tons	Year Installed	Electrical Service	Heating Load, MBH In/Out	Electrical Heater, KW	Supply Air Blower, HP or AMP.	Economizer Functioning If applic.	Priority
1	Bldg. S (VC)	S (AC 1-3)	PKG G/E	Carrier	DF	48HJH004-M-541HQ	2306G40398	3	2006	230/3	72/59	N/A	5.8 A	Yes	1
2	Bldg. S (VC)	S (AC 1-1)	PKG G/E	Carrier	DF	48HJH006-M-541HQ	2106G20323	5	2006	230/3	115/93.2	N/A	7.5 A	Yes	1
3	Bldg. S (VC)	S (AC 1-12)	PKG G/E	Carrier	DF	48HJH006-M-541HQ	2106G20326	5	2006	230/3	115/93.2	N/A	7.5 A	Yes	1
4	Bldg. S (JR)	S	PKG G/E	Carrier	DF	48HJH004-M-541HQ	2306G40399	3	2006	208-3	72/59	N/A	5.8 FLA	Yes	1
5	Bldg. S (JR)	S	PKG G/E	Carrier	DF	48HJH004-M-541HQ	2306G40401	3	2006	208-3	72/59	N/A	5.8 FLA	Yes	1
6	Bldg. S (JR)	S	Mini Split	Mitsubishi	N/A	PUY-A24NHA	52U009638	2	2005	208-1	N/A	N/A	N/A	N/A	1
7	Bldg. S (JR)	S	PKG G/E	Carrier	DF	48HJE008-M-541HQ	2006G40611	7.5	2006	208-3	180/98	N/A	10.6 FLA	Yes	1
8	Bldg. S (JR)	S	PKG G/E	Carrier	DF	48HJE008-M-541HQ	2006G40612	7.5	2006	208-3	180/98	N/A	10.6 FLA	Yes	1
9	Bldg. S (JR)	S	PKG G/E	Carrier	DF	48HJH004-M-541HQ	2306G40402	3	2006	208-3	72/59	N/A	5.8 FLA	Yes	1
10	Bldg. S (JR)	S	PKG G/E	Carrier	DF	48HJH004-M-541HQ	2306G40403	3	2006	208-3	72/59	N/A	5.8 FLA	Yes	1
11	Bldg. S (JR)	S	PKG G/E	Carrier	DF	48HJH006-M-541HQ	2106G20325	5	2006	208-3	105/92	N/A	7.5 FLA	Yes	1
12	Bldg. S2 (JR/VC)	Entire House	Split GE	York	Split	ODU: H4DH060S06A IDU: P4HJ020L10401A	ODU: WVKM027669 IDU: WVKM025344	5	2001	208-1	130/104	N/A	N/A	N/A	1
13	Bldg. N (VC)	N10	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2
14	Bldg. N (VC)	N11	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2
15	Bldg. N (VC)	Gym	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2
16	Bldg. N (VC)	Gym	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2
17	Bldg. N (VC)	Gym	Hydronic Heat	Herman Nelson	SD	No nameplate data								No Econo	Phase 2

SitelogIQ HVAC Audit Form

Site: Allen Hancock Community College

Date: 7/1/2021

Auditor: VC, JR

	School Site	Classroom # or Area Served	Unit Type	Manufacturer	Configuration	Model #	Serial #	Nominal Tons	Year Installed	Electrical Service	Heating Load, MBH In/Out	Electrical Heater, KW	Supply Air Blower, HP or AMP.	Economizer Functioning If applic.	Priority
1	Bldg. N (VC)	Gym	Hydronic Heat	Herman Nelson	SD	No nameplate data						No Econo	Phase 2		
2	Bldg. N (VC)	Mens Locker	Radiant Heater	N/A	N/A	No nameplate data						No Econo	Phase 2		
3	Bldg. N (VC)	Mens Locker	Radiant Heater	N/A	N/A	No nameplate data						No Econo	Phase 2		
4	Bldg. N (VC)	Mens Locker	Radiant Heater	N/A	N/A	No nameplate data						No Econo	Phase 2		
5	Bldg. N (VC)	Mens Locker	Radiant Heater	N/A	N/A	No nameplate data						No Econo	Phase 2		
6	Bldg. N (VC)	Mens Locker	Radiant Heater	N/A	N/A	No nameplate data						No Econo	Phase 2		
7	Bldg. N (VC)	Mens Locker	Radiant Heater	N/A	N/A	No nameplate data						No Econo	Phase 2		
8	Bldg. N (VC)	Mens Locker	Radiant Heater	N/A	N/A	No nameplate data						No Econo	Phase 2		
9	Bldg. N	N128	Hydronic Heat	Herman Nelson	SD	No nameplate data						No Econo	Phase 2		
10	Bldg. N	N132	Hydronic Heat	Herman Nelson	SD	No nameplate data						No Econo	Phase 2		
11	Bldg. N	N13	Hydronic Heat	Herman Nelson	SD	No nameplate data						Yes	Phase 2		
12	Bldg. N	N13	Hydronic Heat	Herman Nelson	SD	No nameplate data						Yes	Phase 2		
13	Bldg. N	N15	Hydronic Heat	Herman Nelson	SD	No nameplate data						No Econo	Phase 2		
14	Bldg. N	Womens Locker	Gas Furnace	Modine	SD	DJE400AFM	2010694	N/A	1994	115/1	400/320	N/A	N/A	100% OSA	Phase 2
15	Bldg. N	Offices	Gas Furnace	Modine	SD	DJE400AFM	2010694	N/A	1994	115/1	400/320	N/A	N/A	100% OSA	Phase 2
16	Bldg. N (JR)	N131	FC	AAF	SD	ABAACAAA40011010	90AXAH00297	-	2000	115/1	N/A	N/A	1/8 HP	N/A	Phase 2
17	Bldg. O 100	O (AC-105)	PKG GE	Carrier	DF	48HCLA06A2A6A0A0A0	2013C83707	5	2013	460/3	60/50	N/A	3.4 A	Yes	3

SitelogIQ HVAC Audit Form

Site: Allen Hancock Community College

	School Site	Classroom # or Area Served	Unit Type	Manufacturer	Configuration	Model #	Serial #	Nominal Tons	Year Installed	Electrical Service	Heating Load, MBH In/Out	Electrical Heater, KW	Supply Air Blower, HP or AMP.	Economizer Functioning If applic.	Priority
1	Bldg. O 100 (VC)	O (AC-104)	PKG G/E	Carrier	DF	48HCLA05A2A6A0A0A0	0913C76644	4	2013	460/3	60/50	N/A	2.5 A	Yes	3
2	Bldg. O 100 (VC)	O (AC-103)	PKG G/E	Carrier	DF	48HCLA06A2A6A0A0A0	2013C83704	5	2013	460/3	60/50	N/A	3.4 A	Yes	3
3	Bldg. O 100 (JR)	O110	PKG G/E	Carrier	DF	48NLVA2404030--	2213C07920	2	2013	208-1	40/32	N/A	1/2 HP	Yes	3
4	Bldg. O 100 (JR)	O108/104	PKG G/E	Carrier	DF	48HCLA05A2A6A0A0A0	0813C75804	4	2013	460-3	60/50	N/A	2.5 FLA	Yes	3
5	Bldg. O 100 (JR)	O101/103	PKG G/E	Carrier	DF	48HCLA04A2A6A0A0A0	2013C65006	3	2013	460-3	60/50	N/A	2.6 FLA	Yes	3
6	Bldg. O 100 (JR)	O111	HP	Carrier	Mini Split	38HDF024-301	1913X92797	2	2013	208-1	N/A	N/A	N/A	N/A	3
7	Bldg. O200 East (JR)	O202	PKG G/E	Carrier	DF	48HCLA05A2A6A0A0A0	0813C75807	4	2013	460-3	60/50	N/A	2.5 FLA	Yes	3
8	Bldg. O200 East (JR)	O201	PKG G/E	Carrier	DF	48HCLA05A2A6A0A0A0	0813C75803	4	2013	460-3	60/50	N/A	2.5 FLA	Yes	3
9	Bldg. O200 West (JR)	O210	PKG G/E	Carrier	DF	48HCLA06A2A6A0A0A0	2013C83706	5	2013	460-3	60/50	N/A	3.4 FLA	Yes	3
10	Bldg. O200 West (JR)	O209	PKG G/E	Carrier	DF	48HCLA06A2A6A0A0A0	2113C83958	5	2013	460-3	60/50	N/A	3.4 FLA	Yes	3
11	Bldg. R2 (JR)	R2 111B	Split Gas	Arcoaire	Split	ODU: AG024GB1 IDU: No access to nameplate	ODU: L97185060 IDU: No access to nameplate	2	ODU: 1997	ODU: 208/1	Nameplate Unreadable				1
12	Bldg. R (JR)	R100A	Split Gas	Bryant	Split	ODU: 561CJ024-D IDU: CKSAXA024000AAA	ODU: 1599E12685 IDU: 2498X24754	2	1999	208-1	N/A	N/A	N/A	N/A	1
13	Bldg. Q (VC)	Q	PKG G/E	ICP	DF	PGAD36D11A	L9805 22959	3	1998	460/3	90/70	N/A	0.75 HP	No Econo	1
14	Bldg. Q (VC)	Q	PKG G/E	ICP	DF	PGAD60E11A	L9804 84496	5	1998	460/3	115/91	N/A	1 HP	No Econo	1
15	Bldg. Q (VC)	Q	PKG G/E	ICP	DF	PGD436090L001E1	C173201688	3	2017	460/3	90/72	N/A	3/4 HP	No Econo	4
16	Bldg. Q (VC)	Q	PKG G/E	ICP	DF	PGA47D11A	L9809 99388	4	1998	460/3	90/71	N/A	0.5 HP	No Econo	1
17	Bldg. Q (VC)	Q	PKG G/E	Trane	DF	YSC060A4ELA0000	748102559L	5	2007	460/3	60/48	N/A	1 HP	Yes	2

